


ORIGINAL



0000113944

RECEIVED

2010 JUL -9 P 3:22

AZ CORP COMMISSION
DOCKET CONTROL

P.O. Box 38
15996 Ironwood Drive,
Dolan Springs, AZ 86441
928-767-3713 Fax: 928-767-3053

July 5th, 2010

Compliance Department
Arizona Corporation Commission
1200 W. Washington St.
Phoenix, AZ 85007

Re: Docket W-02105A-03-0303 Decision 67162
W-02105A-04-0880

Here is our quarterly water report for the second quarter of 2010. Old meters are being replaced on an ongoing basis to improve water loss. Our water loss has been steadily improving since July of 2009.

Please let me know if you have any questions.
Thank you.

A handwritten signature in black ink that reads "Michelle Monzillo". There is a small superscript "6" above the "o" in Monzillo.

Michelle Monzillo
Business Administrator
Mt. Tipton Water Co.

Arizona Corporation Commission

DOCKETED

JUL -9 2010

DOCKETED BY	Handwritten initials or signature in black ink.
-------------	---

Mt. Tipton Water Company Water Pumped and Sold
1st, 2nd, 3rd & 4th Quarters 2010
Docket No. W-20105A-03-0303 and Decision No. 67162

Month	Gal. Sold	Gal. Pumped	Gal. Lost	% Mth Loss	% Qtrly Loss	% Yrly Lost	# of Cust.
January	1,804,546	2,723,151	918,605	33.7%			696
February	2,612,992	2,414,135	-198,857	-8.2%			695
March	2,319,944	2,368,844	48,900	2.1%			690
1st Qtr	6,737,482	7,506,130	768,648		9.2%		
This quarter we had 3 line breaks, 25 blow offs and 14 over flows.							
We installed 17 new meters. Negative water loss in Feb. due to billing cycle being longer than the calendar month.							
April	2,895,816	2,910,970	15,154	1.0%			695
May	2,389,520	3,052,155	662,635	21.7%			692
June	3,512,630	3,516,856	4,226	0.1%			693
2 nd Qtr	8,797,966	9,479,981	682,015		7.6%		

We had an enormous line break in early May that was not discovered for at least half a day. There was 1 other small line break this quarter. We had 5 small overflows trying to regulate the tanks. There were 5 blow offs. We installed 34 new meters.